

## City of Santa Clara

Building Division 1500 Warburton Ave. Santa Clara, CA 95050 www.santaclaraca.gov Building Division: 408-615-2440 Email: Building@santaclaraca.gov Permit Center: 408-615-2420

Email: PermitCenter@santaclaraca.gov

Automated Inspection Scheduling System: 408-615-2400

## FIRE PREVENTION AND HAZARDOUS MATERIALS DIVISION PLAN REVIEW ROUTING SHEET

## Fire Prevention and Hazardous Materials Division – 408-615-4970

Building permit applications noted below in "**Bold**" must be routed to the Fire Prevention and Hazardous Materials Division. Fees must be collected at the Permit Center at the time of application (25% of the Building Division's fee, but not less than \$230.82).

All applications noted in "*Italics*" and not bolded require the applicant to submit directly to the Fire Prevention and Hazardous Materials Division, and make payment of associated fees.

- 1. Addressing (commercial or residential);
- 2. Alternative Materials and Methods (involving fire and life safety);
- 3. Change of occupancy or use;
- 4. Commercial cooking exhaust hoods (Type I Only);
- 5. Commercial solar photovoltaic power systems;
- 6. Construction projects exceeding 1,000 square feet (new of tenant improvement);

## **Exceptions**:

- 1) B-Occupancies tenant improvement of less than 12,000 square feet;
- 2) R-3 Occupancies (Single-Family Residences);
- 7. Cooking oil storage tanks;
- 8. Demolition Applications;
- 9. Dust collection systems (wood, metal, fibers);
- 10. Environmental Reports;
- 11. Exhaust hoods (except Type II);
- 12. Gate and/or barrier installed across emergency vehicle access roadways;
- 13. Generators;
- 14. High-piled storage greater than 500 ft.2 and 12' in height to the top of the storage (6'for high-hazard commodities, which may include tire, combustible liquids, paper, wood);
- 15. Industrial Ovens;
- 16. Medical Gas Systems;
- 17. Mechanical, electrical, and plumbing system associated with hazardous materials;
- 18. Liquefied Petroleum Gas Systems;
- 19. Parking lot and landscape plans that impact fire department access or fire hydrant placement;
- 20. R-3 conversions to residential care facilitates;
- 21. Solar photovoltaic power systems (commercial system only; Bldg. to review residential systems);
- 22. Stationary Storage Battery Systems;
- 23. Spray Booths;
- 24. Tents and other membrane structures: